

CERTIFICATE OF COMPLIANCE

Certificate Number 20150120-E300707
Report Reference E300707-20051018
Issue Date 2015-JANUARY-20

Issued to: SCHURTER AG
8-12 WERKHOFSTRASSE PO BOX 4168 CH-6002
LUZERN SWITZERLAND

**This is to certify that
representative samples of**

UNIVERSAL MODULAR FUSES
Universal Modular Fuse, Type UMT 250, rated 0.315 – 4.0
A, 125 Vdc and 250 Vac. Fuse types include additional
suffix numbers
Time/Current Characteristic: "T"(125% >60 min, 200% <2
min, 1000% 0.01-0.100 s)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

Universal Modular Fuse-links, IEC 60127-4
See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

