CERTIFICATE

Issued to: Applicant: Shenzhen Baohing Electric Wire & Cable Mfr. Co., Ltd. Buchong Tongfuyu Industry Area, Shajing Road, Shajing Street, Baoan District, 518104 Shenzhen,

China

Manufacturer/Licensee:

Shenzhen Baohing Electric Wire & Cable Mfr. Co., Ltd.

Buchong Tongfuyu Industry Area, Shajing Road, Shajing Street, Baoan District, 518104 Shenzhen, China

Product	:	Flexible cables with thermoplastic PVC insulation	n
Trade name	:	BAOHING	
Туре	:	H05VV-F and H05VVH2-F	

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 50525-1:2011 and EN 50525-2-11:2011 clause 4.2
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 958809

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 21 August 2013 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2162708.02

DEKRA Certification B.V.

Drs. G.J. Zoetbrood Managing Director

H.R.M. Barends Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH COUNCIL FOR ACCREDITATION





DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands T +31 88 96 83000 F +31 88 96 81000 www.dekra-certification.com Registered Arnhem 09085396

> DEKRA



ANNEX TO KEMA-KEUR CERTIFICATE 2162708.02

page 1 of 1

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data product trade name type rated voltage conductors insulation sheath	 Flexible cables with thermoplastic PVC insulation BAOHING H05VV-F and H05VVH2-F 300/500 V Copper class 5 PVC compound type TI 2 to EN 50363-3 PVC compound type TM 2 to EN 50363-4-1
Product data - type H05VV-F tested cables certified cables	 3G0,75mm² (white sheathed) 2x1,5mm² (black sheathed) 3G1,5mm² (black sheathed) 2-3 x 0,75-1,5mm² (all colours)
Product data - type H05VVH2-F tested cable certified cables TESTS	 2x0,75mm² (white sheathed) 2x0,75-1,0mm² (all colours)

Test requirements

EN 50525-1:2011 EN 50525-2-11:2011 clause 4.2

Test result

The test results are laid down in DEKRA test file 2162708.02.

Remarks

This KEMA-KEUR certificate is also based on and replaces certificate 2094348.02 of August 21, 2006

Conclusion

The examination proved that all test requirements were met.

Tested by Checked by : R. van Daalen : A.A. Mackenbach

Factory locations

Shenzhen Baohing Electric Wire & Cable Mfr.Co., Ltd. Buchong Tongfuyu Industry Area, Shajing Road, Shajing Street, Baoan District, 518104 Shenzhen, China

Suzhou Baohing Electric Wire & Cable Co., Ltd. No. 9 Yanghua Road, 215021 Suzhou Industrial Park Suzhou, Jiangsu China